



TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.
(TEXTILE TESTING INSTITUTE)
Certification body for the certification of products
Václavská 237/6, 603 00 Brno, Czech Republic

issues



Client: **KE Fibertec AS, Industrivej Vest 21, DK-6600 Vejen, Denmark**
ID: 19138038

TYPE CERTIFICATE

No. 19 – 049/2

Product: **MultiWeave® – variants MW 20, MW 40, MW 80, MW 320, MW 600**
textile material with antibacterial treatment, used in textile based ventilation
- material composition: 100 % polyester
- mass per unit area: 230 - 330 g.m⁻²

This certificate shows the conformity of the products with the following technical specification:

- **EN ISO 20645:2004 Textile fabrics - Determination of antibacterial activity - Agar diffusion plate test**
- **EN ISO 20743:2013 Textiles - Determination of antibacterial activity of textile products (Annex E – Absorption method)**

Based on a joint evaluation of the results of both test methods, good antibacterial activity of the antibacterial treatment on the textile material was proved, both on the new sample and on the sample after 3 washing cycles.


Certification system: Type testing.

The base for the Certificate is the Final Protocol No. COV/19/201/2-2 from 12.08.2019 issued by Certification Body Textile Testing Institute in Brno. Final Protocol is an inseparable part of the Certificate.



Certificate issued:
Brno 13.08.2019
Validity up to: 31.08.2022




Ing Svatava Horáčková
Head of certification department